

Mail & Email information for report date:

5/15/19 17:41

C016008

Due to the increase in operational costs, Aqua-Tech Laboratories will be implementing a slight price increase. The new price list will be effective June 1, 2019.

Aqua-Tech values you as a customer and encourages you to speak with accounting staff at 979-778-3707 ext. 4 or [accounting@aquatechlabs.com](mailto:accounting@aquatechlabs.com) if you have questions.

Thank you for your business,  
June M. Brien  
Executive Technical  
Director

[dpepin@sunsetvalley.org](mailto:dpepin@sunsetvalley.org)

Sunset Valley, City of

Attn: Daniel Pepin

3205 Jones Road

Sunset Valley, TX 78745

**CORPORATE OFFICE**

635 Phil Gramm Boulevard  
Bryan, TX 77807  
Phone: (979) 778-3707  
Fax: (979) 778-3193



**AUSTIN OFFICE**  
7500 Hwy 71 W, Suite 105  
Austin, TX 78735  
Phone: (512) 301-9559  
Fax: (512) 301-9552

The analyses summarized in this report were performed by Aqua-Tech Laboratories, Inc. unless otherwise noted. Aqua-Tech Laboratories, Inc. holds accreditation from the State of Texas in accordance with TNI and/or through the TCEQ Drinking Water Commercial Laboratory Approval Program.

**The following abbreviations indicate certification status:**

- NEL TNI accredited parameter.
- ANR Accreditation not required by the State of Texas.
- DWP Accreditation through the TCEQ Drinking Water Commercial Laboratory Approval Program.
- INF Aqua-Tech Laboratories, Inc. is not accredited for this parameter. It is reported on an informational basis only.

Subcontracted data summarized in this report is indicated by "Sub" in the Lab column.

**General Definitions:**

- NR Not Reported.
- RPD Relative Percent Difference.
- % R Percent Recovery.
- dry Results with the "dry" unit designation are reported on a "dry weight" basis.
- SQL The Sample Quantitation Limit is the value below which the parameter cannot reliably be detected. The SQL includes all sample preparations, dilutions and / or concentrations.
- Adj MDL The Adjusted Method Detection Limit is the MDL value adjusted for any sample dilutions or concentrations.
- MDL The Method Detection Limit is the lowest theoretical value that is statistically different from zero for a specific method, taking into account all preparation steps and instrument settings.

All samples are reported on an "as received" basis unless the designation "dry" is added to the reported unit.

Copies of Aqua-Tech Laboratories, Inc. procedures and individual sampling plans are available upon request. Note that samples are collected by Aqua-Tech Laboratories, Inc. personnel unless otherwise noted in the "Sample Collected" field of this report as "Client" or "CLT".

Samples included in this report were received in acceptable condition according to Aqua-Tech Laboratories, Inc. procedures and 40 CFR, Chapter I, Subchapter D, Part 136.3, TABLE II. - *Required containers, preservation techniques, and holding times*, unless otherwise noted in this report.

**Record Retention:**

All reports, raw data, and associated quality control data are kept on file for 10 years before being destroyed. Any client that would like copies of records must contact Aqua-Tech Laboratories, Inc. no later than six months prior to the scheduled disposal. An administrative fee for retrieval and distribution will apply.



TCEQ DW Lab ID TX 239

This report was approved by:

A handwritten signature in black ink that reads "June M. Brien".

June M. Brien, Technical Director

The results in this report apply only to the samples analyzed. This analytical report must be reproduced in its entirety unless written permission is granted by Aqua-Tech Laboratories, Inc.

[corp@aquatechlabs.com](mailto:corp@aquatechlabs.com)

[www.aquatechlabs.com](http://www.aquatechlabs.com)

**CORPORATE OFFICE**  
 635 Phil Gramm Boulevard  
 Bryan, TX 77807  
 Phone: (979) 778-3707  
 Fax: (979) 778-3193



**AUSTIN OFFICE**  
 7500 Hwy 71 W, Suite 105  
 Austin, TX 78735  
 Phone: (512) 301-9559  
 Fax: (512) 301-9552

**Drinking Water Report**

Sunset Valley, City of

Report Printed: 5/15/19 17:41

C016008

Public Water System Name	County	Type of System	Public Water System ID
CITY OF SUNSET VALLEY	TRAVIS	Public	TX2270004

Sample Name	Sample Collection	Chlorine Residual (mg/L)		Lab Chlorine Check	Total Coliform	E. coli	Received C-O-C #	Analyzed SM9223 B 2004	Laboratory ID	Reject Codes and Qualifiers
		Free	Total							
32 PILLOW	5/13/19 11:00 Daniel Coupe		2.4	A	Absent	Absent	05/13/19 11:46 292527	05/13/19 17:18 KT (Austin)	C016008-01	

MAY19

**Notes & Explanation of Qualifiers**

**Drinking Water - Quality Control Report**

Sample Name	Laboratory ID	QC Sample Result	Source Result	QC Status	QC Check	Analyzed	Qualifier(s)
Blank	M098379-BLK1	Total Coliform	Absent	N/A	Acceptable	05/13/19 17:18 KT	
		E. coli	Absent	N/A	Acceptable		
Duplicate	M098379-DUP1 (C015995-02)	Total Coliform	Absent	Absent	Acceptable	05/13/19 17:18 KT	
		E. coli	Absent	Absent	Acceptable		



# DRINKING WATER (P/A) COLIFORM SUBMISSION FORM



Aqua-Tech Laboratories, Inc.

Austin Bryan  
7500 Hwy 71 W Suite 105 Austin, TX 78735 512.301.9559  
635 Phil Gramm Blvd. Bryan, TX 77807 979.778.3707

Work Order / C-O-C

292527

Test results meet all accreditation/certification requirements unless stated otherwise.

TCEQ Lab ID: TX 239

## Public/Private Water System Identification & Sample Collection Information

Public Water System ID TX 2270004  
(Must be 7 digits, include all zeros)

Public Water System Name City of Sunset Valley  
County Travis

Name City of Sunset Valley  
Address 3205 Jones Rd  
City Sunset Valley  
State / Zip TX 78745  
Phone # (512) 891-9103  
Other Contact

**\* DEFINITIONS**  
CM / CTU - Custody Maintained by custody seal and/or physical possession of samples / Custody Transfer Unbroken indicated by transfer dates & times.

"On Ice" requirement may also be satisfied by refrigerating samples.

All samples are grab samples in 120 mL sterile plastic with sodium thiosulfate unless otherwise noted below.

**Sampler Information**  
Name (Printed) Daniel Coupe  
Operator License # W00042091

Signature *Daniel Coupe*  
Owner  Operator  Other:

Falsification of this form or tampering with water samples is a crime punishable under state and/or federal law. (Texas Penal Code, Title 8, Chapter 37.10) By signing this form, the sampler acknowledges that samples were collected according to the systems established sample collection procedures, and that all information is accurate.

Please write comments below

### Sample Custody

Relinquished by (print & sign) <i>Daniel Coupe</i>	Sampler	Date & Time 5-13-19 11:46am	<input checked="" type="checkbox"/> On Ice + <input type="checkbox"/> Custody Sealed
Received by (print & sign)	Client ATL Field	Date & Time	<input type="checkbox"/> On Ice + <input type="checkbox"/> CM / CTU +
Relinquished by (print & sign)	Client ATL Field	Date & Time	<input type="checkbox"/> On Ice + <input type="checkbox"/> CM / CTU +
Received by (print & sign)	Client ATL Field	Date & Time	<input type="checkbox"/> On Ice + <input type="checkbox"/> CM / CTU +
Relinquished by (print & sign)	Client ATL Field	Date & Time	<input type="checkbox"/> On Ice + <input type="checkbox"/> CM / CTU +
Received by (print & sign) Kelly Kukowski	Lab	Date & Time 5-13-19 11:46	<input checked="" type="checkbox"/> Cond Good <input type="checkbox"/> CM / CTU +

Cooler ID *20A* Samples Iced?  Yes  No Temperature (°C) 17.6 / 17.6 Thermometer ID 0715570

Client Identifier	Sample Identification/Location		Sample Type (check one)				Collected			REPLACEMENT	Originating Sample(s)		Chlorine Residual		Laboratory Use Only			
	Use Specific Address/Location identified in Sample Siting Plan		Routine (Distribution)	Repeat	Raw Well	Special *	Construction *	Date			Time	All Repeat, Replacement & Triggered Raw Samples must include the originating positive information below		Free mg/L	Total mg/L	Rejection Code (if applicable) - Please Resubmit	Laboratory Sample ID Number	
	Raw Wells Use Source ID for Well Sampled Example: G1234567A							Month	Day			Year	Sample ID				Date	Sample ID
15	32 Pillow		<input checked="" type="checkbox"/>					5	13	19	11:00			2.4		C016008	-01	A
																	-02	
																	-03	
																	-04	
																	-05	
																	-06	
																	-07	
																	-08	
																	-09	
																	-10	
																	-11	

Form instructions: [www.tceq.texas.gov/drinkingwater/microbial/revised-total-coliform-rule](http://www.tceq.texas.gov/drinkingwater/microbial/revised-total-coliform-rule)

\* Special and Construction samples are NOT FOR COMPLIANCE

EH - Exceeds Holding Time  
LA - Lab Accident  
VO - Insufficient Volume

NC - No Chlorine Residual  
HB - Heavy Bacterial Growth  
BP - Invalid Sampling Point

EV - Excessive Volume  
LT - Leaked in Transit  
FZ - Frozen Sample

CL - Chlorine Present  
AR - Agency Rejected  
IP - Invalid Sampling Protocol

BR - Broken  
IN - Insufficient Sampling Information  
ST - Heavy Silt or Turbidity Present

LR - Lab Rejected  
V-0022R02  
(From TCEQ 10525 08/2017)